

ADDENDUM NO. 1
August 26, 2026

ROSAMOND COMMUNITY SERVICES DISTRICT

SCADA UPGRADE PROJECT
3179 35th Street West, Rosamond, CA 93560

Project No. 12401-22401

- Item No. 1:** Document 00 1113 Section 1.01 change to: "Project description: The project, in general, consists of replacing (4) aging programmable logic controllers (PLC) and their respective ancillary components within the PLC enclosures or communication equipment at the admin building, Tank 1, Tank 2, Tank 3, Tank 4, Tank 5, Well 8, Well 9, Sierra Hwy Turnout, 25th St Turnout, 35th St Turnout, ICP 1 (WWTP), ICP 2 (WWTP), and ICP 3 (WWTP). The District requires the updated PLC programming to function and provide the same features as the existing units. In summary, the District requires procurement, fabrication, function testing, programing, and commissioning of the new PLC and communication equipment and enclosures."
- Item No. 2:** Document 00 0101, Title Page, change "Required Contractor's License Classification: Class A" to "Required Contractor's License Classification: Class A or C-10".
- Item No. 3:** Document 00 1113, Notice to Contractors, Paragraph 2.01, change 'A California "A" . . .' to 'A California "A", or "C-10" . . . '.

The following Addendum was issued, modifying the Project Manual:

- Addendum No. 1, issued on August 27, 2026.



Kim Domingo
General Manager

Contractor

Signature

Date

Name/Title