

DOCUMENT 00 9111

ADDENDUM NO. ONE

August 20, 2026

ROSAMOND COMMUNITY SERVICES DISTRICT

Admin Building Standby Generator Replacement

3179 35th Street West, Rosamond, CA 93560

Project Nos. 12609, 22609

- Item No. 1:** Document 00 0101, Title Page, change "Required Contractor's License Classification: Class A" to "Required Contractor's License Classification: Class A, B or C-10".
- Item No. 2:** Document 00 1113, Notice to Contractors, Paragraph 2.01, change 'A California "A" . . .' to 'A California "A", "B" or "C-10" . . . '.
- Item No. 3:** Sheet E03, Demolition Notes, Keynote 2, revise keynote to read: DISPOSE THE GENERATOR AND ALL ITS COMPONENTS OFF-SITE IN ACCORDANCE WITH ENVIRONMENTAL REGULATIONS
- Item No. 4:** Sheet E04, Demolition Notes, General Note 1, revise note to read: DISPOSE THE GENERATOR AND ALL ITS COMPONENTS OFF-SITE IN ACCORDANCE WITH ENVIRONMENTAL REGULATIONS
- Item No. 5:** Sheet E05, Conduit & Wire Schedule, Conduit L-002, change conduit size from 2 to 1".

The following Addenda were issued, modifying the Project Manual:

Addendum No. 1, issued on August 20, 2026.


Kim Domingo
General Manager

Contractor

Signature

Date

Name/Title

END OF DOCUMENT