

ADDENDUM NO. 2

Date: July 9, 2026

ROSAMOND COMMUNITY SERVICES DISTRICT

TANK 3 RECOAT PROJECT

3179 35th Street West, Rosamond, CA 93560

Project No. 12512

NOTICE IS HEREBY GIVEN to bidders and plan holders that in reference to the contract documents of the above-mentioned project, the following will be noted:

Item No. 1: Question: Does the District have an estimated quantity, depth, or volume of sediment, sludge, residual water, or debris currently inside Tank 3 that will need to be cleaned and removed prior to surface preparation and recoating?

Answer: The estimated quantity is less than 10 cubic yards.

Item No. 2: Question: As the Contractor, are we responsible for sampling, profiling, manifesting, and coordinating disposal of any sediment, sludge, residual material, spent abrasive, or coating debris removed from the tank?

Answer: Yes.

Item No. 3: Question: Does the District have a recommended or approved disposal site for sediment, sludge, or residual material removed from Tank 3?

Answer: The sediment may be spread at the tank site.

Item No. 4: Question: Please confirm the allowable working hours for this project. Are contractors restricted to standard 8-hour workdays, or would 10-hour workdays be allowed with prior approval?

Answer: A four-day, ten-hour work schedule may be accommodated with prior approval.

Item No. 5: Question: Will a plan holders list or mandatory job walk attendance list be issued for this project so contractors and subcontractors can review who attended?

Answer: The list is available upon request.

The following Addenda were issued, modifying the Project Manual:

Addendum No.1, issued on July 8, 2026.

Addendum No.2, issued on July 9, 2026.



Amanda C. Parra, PE
Engineer

Contractor

Signature

Date

Name/Title

END OF DOCUMENT